



Product Approval
USER: Public User

[Product Approval Menu](#) > [Product or Application Search](#) > [Application List](#) > **Application Detail**

OFFICE OF THE SECRETARY

FL # FL42024
Application Type New
Code Version 2020
Application Status Approved



Comments Archived

Product Manufacturer GAVIOTA
Address/Phone/Email Cerrada Acalotenco 237 Bodega 48
Col San Sebastian. Parque Industrial Pical Pantaco
Delegacion Azcapotzalco, NON-US

Authorized Signature Francisco Cano

Technical Representative
Address/Phone/Email

Quality Assurance Representative
Address/Phone/Email

Category Impact Protective Systems
Subcategory Operable

Compliance Method Evaluation Report from a Florida Registered Architect or a Licensed Florida Professional Engineer
 Evaluation Report - Hardcopy Received

Florida Engineer or Architect Name who developed the Evaluation Report Walter A. Tillit Jr., P.E.
Florida License PE-44167
Quality Assurance Entity National Accreditation and Management Institute
Quality Assurance Contract Expiration Date 12/31/2023
Validated By John W. Knezevich, PE
 Validation Checklist - Hardcopy Received



04/18/2023

Certificate of Independence [FL42024 R0 COI COI DRAWING 22-066 GAVIOTA IMPACT PROTECTIVE ROLLING SYSTEM.](#)

Referenced Standard and Year (of Standard)	Standard	Year
	TAS 201	1994
	TAS 202	1994
	TAS 203	1994

Equivalence of Product Standards Certified By

Sections from the Code

Product Approval Method

Method 1 Option D

Date Submitted

04/17/2023

Date Validated

04/18/2023

Date Pending FBC Approval

04/23/2023

Date Approved

06/20/2023

Summary of Products

FL #	Model, Number or Name	Description
42024.1	Impact Protective Rolling System with GV-60 End Retention Slat (H.V.H.Z.)	Extruded aluminum slats interlocked together thru knuckles and retained by tracks to provide hurricane protection.
Limits of Use Approved for use in HVHZ: Yes Approved for use outside HVHZ: No Impact Resistant: Yes Design Pressure: +60/-60 Other: Large missile impact resistant (basic protection only). Pressure rating: +60, -60 psf at 170-3/16" span with 1/4" slip for installation into existing poured concrete walls (wall mounted). See sheets 13 and 17 of installation drawing for additional specs. Reference Section 7 of the Product Evaluation Report for additional limitations and conditions of use.		Installation Instructions FL42024_R0_II_PED_DRAWING_22-066_GAVIOTA_IMPACT_PROTECTIVE_ROLLING_SYSTEM Verified By: Walter A. Tillit Jr., P.E. PE 44167 Created by Independent Third Party: Yes Evaluation Reports FL42024_R0_AE_PER_DRAWING_22-066_GAVIOTA_IMPACT_PROTECTIVE_ROLLING_SYSTEM Created by Independent Third Party: Yes

[Back](#)

[Next](#)

Contact Us :: 2601 Blair Stone Road, Tallahassee FL 32399 Phone: 850-487-1824

The State of Florida is an AA/EEO employer. [Copyright 2007-2013 State of Florida](#). :: [Privacy Statement](#) :: [Accessibility Statement](#) :: [Refund Statement](#)

Under Florida law, email addresses are public records. If you do not want your e-mail address released in response to a public-records request, do not send electronic mail to this entity. Instead, contact the office by phone or by traditional mail. If you have any questions, please contact 850.487.1395. *Pursuant to Section 455.275(1), Florida Statutes, effective October 1, 2012, licensees licensed under Chapter 455, F.S. must provide the Department with an email address if they have one. The emails provided may be used for official communication with the licensee. However email addresses are public record. If you do not wish to supply a personal address, please provide the Department with an email address which can be made available to the public. To determine if you are a licensee under Chapter 455, F.S., please click [here](#).

Product Approval Accepts:

